



NOTES: 1) STEEL CASING IS REQUIRED (MIN. 10 mm WALL THICKNESS) FOR ALL BORES GREATER THAN 1.2 m DIA.

2) A MINIMUM OF 1.5 m OF COVER IS REQUIRED OVER ALL BORED PIPING/CONDUIT

BORING & JACKING

NOT TO SCALE

3/9/99

REVISED